



Water Engineering Division

UWM Permit Number

Empty box for UWM Permit Number

Form 4 - Required Backflow Prevention Devices for Proposed Firelines

Please answer the following questions to determine if a reduced pressure principle detector check backflow prevention device will be required for your proposed fireline:

1. Does the private fire protection system include any on-site auxiliary or supplemental water supply sources, such as tanks, reservoirs, or pumps?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
2. Will the fire protection system include the addition of any chemicals or foaming agents?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

A reduced pressure principle assembly backflow prevention device may be required if any questions above have a "Yes" response. Otherwise, if all the responses are "No", a double detector check assembly backflow prevention device will be acceptable. Please contact a Fire Safety Specialist of the Anaheim Fire Department to confirm that the private fire protection system is consistent with the responses provided above.

All water service connections for domestic and irrigation purposes, except for single-family residences, will require a reduced pressure principle backflow prevention device.

In the event the answers you provide on this form later change, then you may be required to change the type of backflow prevention device on your service line.

Applicant's Name

Applicant's Signature

Date