



City of Anaheim
DEPARTMENT OF PUBLIC WORKS

May-15-19

NOTICE TO ALL BIDDERS

PROJECT: Linda Vista Complex Pump Station Improvement Phase 2

ACCOUNT No. 502-521-3724-7865-1800332-01

ADDENDUM NO. 2

This is a modification to the bid package for the project identified above. The attached are additions, revisions and clarifications to the "Contract Documents" and shall become a part of the "Contract Documents". All bidders are required to incorporate all necessary changes, additions or deductions into their proposals. This Addendum includes the following:

1. Question # 1 Regarding Bid Bond Form in Bid Proposal:

"I noticed that the bid proposal does not have an attached bid bond form. Are we required to use our surety's standard bond form? Please clarify and confirm."

- a. **Answer** - The Sample Bond Form is in the "Contract Documents/Special Provisions" as per usual, as part of the Instructions to bidders. SS-4 thru SS-5. The Bid Proposal identifies the requirement of 10% of the total bid price that must also be submitted with your bid, which could be in the form of Cash, Cashier's Check, Certified Check or a Bidder's Bond...

2. Question # 2 Regarding Sheet S-7:

"Sheet S-7, filler panel section D, appears to show two metal supports to hold up the filler panel on both sides, running parallel to the hatches. Please clarify size of metal supports."

- a. **Answer** - Please refer to S-7, Sheet Note 7 "Hatches and filler panels shall be manufactured with trough drains for control of water infiltration". To further clarify, the filler is to be manufactured with a single trough drain channel frame continuous on all sides. Note that the second channel shown in the section view D is the trough drain frame for the access hatch which is next to the filler panel. **See attached sample filler design.** The design shall be such to ensure the system is watertight and manufactured by USF Fabrication, Inc. or approved equal.

3. **New Q & A deadline for Bidder(s) questions or clarifications:**
a. **New Deadline to submit questions or get clarification is before midnight on Thursday May 23rd, 2019**

Bid opening date remains the same, all bids must be received and stamped by the City Clerk's office on the 2nd floor of City Hall located at 200 S. Anaheim Blvd. Anaheim, CA 92805, prior to Thursday before 2:00 p.m. on May 30th, 2019.

All other aspects of the documents pertaining to this project remain in effect and applicable. Payment for complying with those provisions shall be deemed to be included in the price bid for the various items of work. No additional compensation will be allowed therefore.

Sincerely,



Joel C. Jordan
Contract Administration

C: Robert Luciano William J. Grigsby
 Lisa O'Connell Raul Garcia File

The bidder shall individually identify and acknowledge receipt of all addenda by signing and enclosing each addendum form in his/her bid package submittal. Failure to do so may result in a disqualification of his/her bid.

Signature

Date