

TEST RESULTS

April, May 2019

Groundwater well	PFOA	PFOS	PFOA and PFOS
Well 39	5.6	11.5	17.1
Well 40	13.7	32.8	46.5
Well 42	14.4	35.7	50.1
Well 44	9.1	24.5	33.6
Well 45	12.4	29.5	41.9
Well 46	24.5	62.5	87.0
Well 47	5.0	13.8	18.8
Well 48	6.3	20.0	26.3
Well 49	7.6	21.5	29.1
Well 51	not detected	not detected	not detected
Well 52	12.5	40.8	53.3
Well 53	5.3	16.5	21.8
Well 54	17.7	56.5	74.2
Well 55	19.1	43.6	62.7
Well 56	14.4	50.6	65.0
Well 58	15.2	39.3	54.5
Well 59	14.3	34.8	49.1
Linda Vista	13.7	33.2	46.9

Measurements in nanograms per liter, equivalent to parts per trillion.

While the majority of PFOA, PFOS or combined levels above require local notification to local officials, they are *below* federal and state limits for drinking water use.

Wells with concentrations below California's response level remain in service with close monitoring and testing. Should levels in any given well rise to the state's response level, Anaheim Public Utilities will take action.

Wells above that have combined PFOA and PFOS levels above the California's response level have been taken offline in the abundance of caution, and other water sources are being used to serve customers.