



REFERENCES:

1. STATE OF CALIFORNIA, DEPT. OF WATER RESOURCES BULLETIN 74, "WATER WELL STANDARDS"
2. CITY OF ANAHEIM MUNICIPAL CODE, TITLE 10, CHAPTER 10.20

NOTES:

1. ALL WORK SHALL BE DONE UNDER PERMIT ISSUED BY THE UTILITIES DIRECTOR AND SUBJECT TO HIS INSPECTION.
2. CASING TO BE PERFORATED, IF NECESSARY, TO INSURE BACKFILLING OF ANNULAR SPACE OUTSIDE OF CASING.
3. BACKFILL MATERIAL TO BE INTRODUCED UNDER PRESSURE TO CLOSE ALL VOIDS IN GRAVEL PACKED WELLS.
4. ACCEPTABLE BACKFILL MATERIAL TO BE:
 - A. NEAT CEMENT : 5-7 GAL. PER SACK
 - B. CEMENT GROUT : 5-7 GAL. PER SACK, 2 PARTS SAND/1 PART CEMENT
 - C. CONCRETE : CLASS B, 5 SACK/CU. YD.
 - D. BENTONITE (UP TO 5 PERCENT BY WEIGHT OF CEMENT) OR SIMILAR WORKABILITY AGENTS MAY BE USED.

DESTRUCTION OF ABANDONED WATER WELLS

PUBLIC UTILITIES DEPARTMENT

WATER SERVICES		CITY OF ANAHEIM	
BY	DATE	APPROVED	DATE
TL	8-25-91	WATER FIELD/OPER. MGR.	
CHECKED	DATE	APPROVED	DATE
KT	8-13-91	WATER ENGINEERING MANAGER	
SUBMITTED	DATE	APPROVED	DATE
CIVIL ENGR	8-20-91	ASST. GEN. MGR./WATER SERVICES	
WATER			

STD. NO.

W-630

SHEET 1 OF 1

REVISION NO. 2

DATE : MAR 2005