



City of Anaheim
DEPARTMENT OF PUBLIC WORKS

AUGUST 27, 2021

NOTICE TO ALL BIDDERS

PROJECT: WAYFINDING SIGNS PROJECT (RCP2020-17288)
ACCOUNT NO(s). 460-411-S264-7898-CTRCTYWFI; 243-411-S264-7898-CTRCTYWYFI

ADDENDUM NO. 1

This is a modification to the bid package for the project identified above. The attached are additions, revisions and/or clarifications to the "Contract Documents" and shall become a part of the "Contract Documents". All bidders are required to incorporate all necessary changes, additions or deductions into their proposals. This Addendum includes the following:

1. **QUESTIONS AND ANSWERS:**

Q1: Please identify locations for the 600sf of grind/cap/slurry as well as the 100LF of paving.

A1: Per the scope and plans, the street light conduits shall be intercepted in the sidewalk or parkway. The bid items for grind/cap/slurry and paving are to be used only if conduit is required to be intercepted in the street.

THE BID DUE DATE REMAINS THE SAME AS SEPTEMBER 2, 2021, AT 2:00 PM (PDT)

All other aspects of the documents pertaining to this project remain in effect and applicable. Payment for complying with those provisions shall be deemed to be included in the price bid for the various items of work. No additional compensation will be allowed, therefore.

Sincerely,

Brenda Medina
Contract Administration

cc Raul Garcia Earl Schwartz
Rod Yong Manuel Soto
City Clerk File

The bidder shall individually identify and acknowledge receipt of all addenda by signing and enclosing each addendum form in his/her bid package submittal. Failure to do so may result in a disqualification of his/her bid.

Signature

Date