



City of Anaheim
DEPARTMENT OF PUBLIC WORKS

September 9, 2021

NOTICE TO ALL BIDDERS

PROJECT: Central Library Outdoor Space Improvement, Phase II and Euclid Library Outdoor Space

Account No. 235-213-4796-9601 and 235-213-4755-9601

BLD2020-02649, BLD2021-00343, GRA2020-03567

ADDENDUM NO. 1

This is a modification to the bid package for the project identified above. The attached are additions, revisions and clarifications to the "Contract Documents" and shall become a part of the "Contract Documents". All bidders are required to incorporate all necessary changes, additions or deductions into their proposals. This Addendum includes the following:

1. Bidders' Questions and Answers:

Q1 The scope of work description in the bid information mentions the installation of an art piece. What is the art piece?

A1 **See construction Note C-12 for the Euclid Library – Outdoor Space Plans. It is a Sundial with a Masonry pedestal. Information about the sundial and the pedestal are on Sheet L5.3, Detail N of the Euclid Library Outdoor Space Plans.**

Q2 Does this project fall under any type of Project Labor Agreement (PLA) contract?

A2 **No.**

Q3 Could you tell me if this project is subject to a PLA (Project Labor Agreement), a PSA (Project Stabilization Agreement), a CBA (Collective Bargaining Agreement), a CWA (Community Workforce Agreement), or anything of that nature? Please advise

A3 **This Project is not subject to a PLA (Project Labor Agreement), PSA (Project Stabilization Agreement), CWA (Community Workforce Agreement), or CBA (Collective Bargaining Agreement).**

Q4 Can pavers be installed by sub with C27?

A4 Yes, however per Euclid Library – Outdoor Space Specifications, Section 10-6 Permeable Concrete Pavers, Subsection 1.03 Submittals:

“A. Bid Submittals: The Contractor shall submit to the City the following as part of the bid proposal:

1. Paver Installation Subcontractor:

- A. A copy of Subcontractor’s current certificate from the Interlocking Concrete Pavement Institute’s Concrete Paver Installer Certification program.
- B. Job references from three (3) projects of a similar size and complexity. Provide City/Client/General Contractor names, postal address, phone number, and email address.”

2. Pre-Bid Meeting Sign in sheet.

- See Attached.

3. Specifications

- **Delete** ‘Section 2. CDBG Fund Specifications and Documents’, and **Replace** with the revised ‘Section 2. CDBG Fund Specifications and Documents’, issued with this addendum.

Please note that these revised specifications contain the updated Davis Bacon wage rates to be used on the project.

THE BID DATE REMAINS THE SAME AT SEPTEMBER 16, 2021 AT 2:00 PM

All other aspects of the documents pertaining to this project remain in effect and applicable. Payment for complying with those provisions shall be deemed to be included in the price bid for the various items of work. No additional compensation will be allowed therefore.

Sincerely,



Patrick Kelley, E.I.T.
Contract Administrator

C Ana Straabe
Patrick Kelley
Brenda Medina

Naomi Gruenthal
Sachindu Lokukatagoda
Raul Garcia

File

Addendum No. 1, September 9, 2021
Request for Proposals (RFP)

City of Anaheim
Central Library Outdoor Space Improvement,
Phase II and Euclid Library Outdoor Space

The bidder shall individually identify and acknowledge receipt of all addenda by signing and enclosing each addendum form in his/her bid package submittal. Failure to do so may result in a disqualification of his/her bid.

Signature

Print Name

Firm Name

Date