



NOTES:

1. Concrete Shall be Class 500-C-2500.
2. Reinforcing shall be 6"x6" - W 1.4 x W 1.4 welded wire mesh (W.W.M.) or approved equal.
3. Anchors shall be constructed in accordance with standard plan 330 when slope equals or exceeds 2:1.
4. Concrete or Air - Blown mortar shall be colored medium or Dark Earth tones (Black, Tan, Sienna, Amber, Ochre, Green).
5. Air Blown mortar shall be Class 600 -E - 3250.
6. Ground shall be pre - wetted to the satisfaction of the City Field Engineer prior to placement of concrete Moisture loss retardant shall be used when required by the City Field Engineer.
7. Minimum longitudinal grade of interceptor drain shall be 0.50%
8. Interceptor drain shall be required when tributary drainage area with the vertical height is greater than 50 FT. and when slope exceeds 10 to 1.



REVISION	DATE

CITY OF ANAHEIM PUBLIC WORKS ENGINEERING DEPARTMENT	<h1 style="margin: 0;">INTERCEPTOR DRAIN</h1>
6-26-91 DIR. OF PUBLIC WORKS & CITY ENGR. DATE	6-24-91 DEPUTY CITY ENGINEER DATE
STANDARD DETAIL NO. <u>335</u>	