



STRUCTURAL DATA							
WALL AND SLAB DIMENSIONS AND REINFORCEMENT REQUIREMENTS							
MAX W	MAX V	t	F	REINFORCEMENT REQUIRED IN			
				FRONT WALL	REAR WALL	BOTTOM SLAB	END WALL
1.0 m (3.5')	2.4 m (8')	150 mm (6")	150 mm (6")	NO	REINFORCEMENT	REINFORCEMENT	REINFORCEMENT
1.0 m (3.5')	3.5 m (12')	200 mm (8")	200 mm (8")				
2.0 m (7')	1.8 m (6')	150 mm (6")	150 mm (6")				
2.0 m (7')	3.5 m (12')	200 mm (8")	200 mm (8")				
4.0 m (14')	1.2 m (4')	150 mm (6")	150 mm (6")				
4.0 m (14')	2.4 m (8')	150 mm (6")	200 mm (8")				
8 m (26') AND 9 m (29')	3.5 m (12')	200 mm (8")	250 mm (10')	REINFORCEMENT	REINFORCEMENT	REINFORCEMENT	REINFORCEMENT
	1.2 m (4')	150 mm (6")	150 mm (6")				
	1.8 m (6')	150 mm (6")	200 mm (8")				
	2.4 m (8')	200 mm (8")	200 mm (8")				
	3.0 m (10')	200 mm (8")	250 mm (10')				
	3.5 m (12')	200 mm (8")	250 mm (10')				

FOR W > 9 m (28'), V > 3.5 m (12') OR B > 1.2 m (4') SEE PLANS

STANDARD PLANS FOR PUBLIC WORKS CONSTRUCTION

PROMULGATED BY THE PUBLIC WORKS STANDARDS, INC., GREENBOOK COMMITTEE 1984 REV. 1992, 1996	<h2 style="margin: 0;">CURB OPENING CATCH BASIN WITH MANHOLE IN STREET</h2>	STANDARD PLAN METRIC <h1 style="margin: 0;">307-2</h1>
USE WITH STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION		SHEET 1 OF 2

NOTES:

1. WHERE THE BASIN IS TO BE CONSTRUCTED WITHIN THE LIMITS OF EXISTING OR PROPOSED SIDEWALK OR IS CONTIGUOUS TO SUCH SIDEWALK, THE TOP SLAB OF THE BASIN MAY BE POURED EITHER MONOLITHIC WITH THE SIDEWALK OR SEPARATELY, USING THE SAME CLASS OF CONCRETE AS IN THE BASIN. WHEN POURED MONOLITHICALLY, THE SIDEWALK SHALL BE PROVIDED WITH A WEAKENED PLANE OR A 25 mm (1") DEEP SAWCUT CONTINUOUSLY AROUND THE EXTERNAL PERIMETER OF THE CATCH BASIN WALLS, INCLUDING ACROSS THE FULL WIDTH OF THE SIDEWALK. SURFACE OF ALL EXPOSED CONCRETE SHALL CONFORM IN SLOPE, GRADE, COLOR, FINISH, AND SCORING TO EXISTING OR PROPOSED CURB AND WALK ADJACENT TO THE BASIN.
2. ALL CURVED CONCRETE SURFACES SHALL BE FORMED BY CURVED FORMS, AND SHALL NOT BE SHAPED BY PLASTERING.
3. FLOOR OF BASIN SHALL BE GIVEN A STEEL TROWEL FINISH, FLOOR OF MANHOLE CHAMBER SHALL HAVE A LONGITUDINAL AND LATERAL SLOPE OF 1:12 MINIMUM AND 1:3 MAXIMUM SLOPE FLOOR FROM ALL DIRECTIONS TO THE OUTLET.
4. CATCH BASIN SHALL BE CASE A UNLESS OTHERWISE SPECIFIED.
5. DIMENSIONS:
 - W = 2 m (7')
 - B = 500 mm (20")
 - Y = 600 mm (24")
 - V = THE DIFFERENCE IN ELEVATION BETWEEN THE TOP OF THE CURB AND THE INVERT OF THE CATCH BASIN AT THE OUTLET = 3.5 m (4.5').
 - V_I = THE DIFFERENCE IN ELEVATION BETWEEN THE TOP OF THE CURB AND THE INVERT OF THE INLET, NOTED ON THE PLANS.
 - H = NOTED ON THE PLANS.
 - A = THE ANGLE, IN DEGREES, INTERCEPTED BY THE CENTERLINE OF THE CONNECTOR PIPE AND THE CATCH BASIN WALL TO WHICH THE CONNECTOR PIPE IS ATTACHED.
6. PLACE CONNECTOR PIPES AS INDICATED ON THE PLANS. UNLESS OTHERWISE SPECIFIED, THE CONNECTOR PIPE SHALL BE LOCATED AT THE DOWNSTREAM END OF THE BASIN. WHERE THE CONNECTOR PIPE IS SHOWN AT A CORNER, THE CENTERLINE OF THE PIPE SHALL INTERSECT THE INSIDE CORNER OF THE BASIN. THE PIPE MAY BE CUT AND TRIMMED AT A SKEW NECESSARY TO INSURE MINIMUM 80 mm (3") PIPE EMBEDMENT, ALL AROUND, WITHIN THE CATCH BASIN WALL, AND 75 mm (3") RADIUS OF ROUNDING OF STRUCTURE CONCRETE, ALL AROUND, ADJACENT TO PIPE ENDS. A MONOLITHIC CATCH BASIN CONNECTION SHALL BE USED TO JOIN THE CONNECTOR PIPE TO THE CATCH BASIN WHENEVER ANGLE "A" IS LESS THAN 70° OR GREATER THAN 110°, OR WHENEVER THE CONNECTOR PIPE IS LOCATED IN A CORNER. THE OPTIONAL USE OF A MONOLITHIC CATCH BASIN CONNECTION IN ANY CASE IS PERMITTED. MONOLITHIC CATCH BASIN CONNECTIONS MAY BE CONSTRUCTED TO AVOID CUTTING STANDARD LENGTHS OF PIPE.
7. STEPS SHALL BE LOCATED AS SHOWN. IF THE CONNECTOR PIPE INTERFERES WITH THE STEPS, THEY SHALL BE LOCATED ON THE FRONT WALL OF THE MANHOLE CHAMBER OR THE DOWNSTREAM WALL OF THE MANHOLE CHAMBER AND THE MANHOLE MOVED DOWNSTREAM 300 mm (12"). STEPS SHALL BE SPACED 300 mm (12") APART. THE TOP STEP SHALL BE 175 mm (7") BELOW THE TOP OF THE MANHOLE AND PROJECT 65 mm (2-1/2"). ALL OTHER STEPS SHALL PROJECT 130 mm (5").
8. DOWELS ARE REQUIRED AT EACH CORNER AND AT 2.1 m (7') ON CENTER (MAXIMUM) ALONG THE BACKWALL.
9. THE FOLLOWING SPPWC ARE INCORPORATED HEREIN:
 - 308 MONOLITHIC CATCH BASIN CONNECTION
 - 309 CATCH BASIN REINFORCEMENT
 - 310 CATCH BASIN FACE PLATE ASSEMBLY AND PROTECTION BAR
 - 630 610 mm (24") MANHOLE FRAME AND COVER
 - 635 STEEL STEP

STANDARD PLANS FOR PUBLIC WORKS CONSTRUCTION

CURB OPENING CATCH BASIN WITH MANHOLE IN STREET

STANDARD PLAN
METRIC

307-2

SHEET 2 OF 2